



# TOWN OF CULPEPER

## Procurement

400 S Main Street  
Culpeper, VA 22701  
Phone: (540) 829-8242

May 10, 2019

### ADDENDA NO. 1 TO ALL BIDDERS:

Reference – ITB: DES-19-38002  
Title: Annual Water & Wastewater Chemical Bids

The following responses are answers to questions received with regard to the above referenced ITB and constitute Addendum #1. Please acknowledge receipt of this Addendum No. 1. Dated 5/10/19 on the Vendor Information Sheet where indicated when submitting your Bid package or acknowledge if your Bid package has already been mailed. **Failure to acknowledge this addendum may result in your Offer being declared non-responsive.** All other general terms, conditions and specifications shall remain the same.

1. Can you send me the previous bid tabulations? Last year's bid tab has been attached to eVA for vendor review.
2. I am confused about Item 1. It specifies a Trade name product, but says no substitutions. Other items on your bid, 6,7,8,10,13,14, allow for alternate product approval. Can we not get one of our alternates approved for Item 1? The Town of Culpeper is removing "No Substitutions". We will consider any product which meets the specifications cited.

Attachment I, Item 1 name is hereby changed from DeIPAC 1000 to Aluminum Chloride Hydroxide Sulfate. Item 1 shall now read:

Item	Description	Quantity per Delivery	Estimated Total per year
1	Aluminum Chloride Hydroxide Sulfate	22.1 Tons	199 Tons

#### ITEM 1

Aluminum Chloride Hydroxide Sulfate - Specifications %  $Al_2O_3$   $13.5 \pm 0.5$ , % Al  $7.1 \pm 0.3$ , % Basicity  $76 \pm 4$ , % Chloride  $12.5 \pm 2.0$ , Properties pH (neat)  $2.4 \pm 0.3$ , Freezing Point  $<0^\circ F$

Delivery to the Water Treatment Plant, 816 Woodview Rd., Culpeper, VA and Wastewater Treatment Plant, 15108 Service Lane, Culpeper, VA.

  
\_\_\_\_\_  
Lisa Wortman, Procurement Officer